

# TIMILON TECHNOLOGY TEST REPORT

**SCOPE OF WORK** VOC Reduction by EnviroKlenz

REPORT NUMBER 104321905GRR-002

\_\_\_\_\_

ISSUE DATE 09-June-2020

PAGES

9

DOCUMENT CONTROL NUMBER Per GFT-OP-10 (6-March-2017) © 2020 INTERTEK





TEST REPORT FOR TIMILON TECHNOLOGY ACQUISITIONS, LLC

Report No.: 104321905GRR-002 Date: 09-June-2020 P.O.: 2781

## **SECTION 1**

#### **CLIENT INFORMATION**

Attention:Kyle KnappenbergerTimilon Technology Acquisitions, LLC1431 SW Auburn Rd Bldg BTopeka, FL 66615Phone:+1 (785) 246-7074Email:kbk@timilon.com

4700 Broadmoor Ave SE, Suite 200 Kentwood, MI 49512

 Telephone:
 +1 616 656 7401

 Facsimile:
 +1 616 656 2022

 www.intertek.com

Taylor Gebben Project Engineer

Jesse Ondersma, Ph.D. Project Reviewer

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Report No.: 104321905GRR-002 P.O.: 2781

## SECTION 2

## SUMMARY

Date Received:	20-May-2020
Dates Tested:	03-June-2020 to 04-June-2020

#### **DESCRIPTION OF SAMPLES**

Part Name: Model Number: Materials Submitted: Condition of Samples: Shipping Condition: EnviroKlenz Not Specified One (1) Filtration Unit & Three (3) Filter Cartridges Not Specified Good Condition

#### WORK REQUESTED/APPLICABLE DOCUMENTS

VOC Reduction Testing:	Referencing NRCC-54013	
Intertek Quote:	Qu-01068866-2	

#### **TEST SUMMARY**

The purpose of this testing is to determine the efficacy of the filtration unit to remove challenge VOCs. The air purifier was challenged with one VOC representative of what are found in homes: Hydrogen sulfide.

#### SAMPLE DISPOSITION

At the completion of testing, samples were returned to Timilon Technology Acquisitions.

Report No.: 104321905GRR-002 P.O.: 2781

# SECTION 3

## NRCC-54013 SECTION 5.1.2.2.

Date Received:	20-May-2020
Dates Tested:	03-June-2020 to 04-June-2020

#### **DESCRIPTION OF SAMPLES:**

Part Name:	EnviroKlenz
Model Number:	Not Specified
Materials Submitted:	One (1) Filtration Unit & Three (3) Filter Cartridges
Condition of Samples:	Not Specified
Shipping Condition:	Good Condition

#### **TEST PROCEDURE:**

VOC removal testing was performed referencing NRCC-54013 (April 2011): Method for Testing Portable Air Cleaners sections 3.2 and 5.1.2.

Natural system decay for the challenge chemical is performed prior to the test. The unit was placed in the center of a chamber which was sealed. Per clients request the HEPA filter and replacement filter cartridge were adhered together. The challenge chemical (hydrogen sulfide) was injected and allowed to circulate for 30 minutes during which an air sample was taken. An additional enclosure fan was operated to ensure air mixing. The system was then turned on using the highest fan speed beginning the test timing.

VOC samples were collected every 5 minutes for 4 hours after starting the system. Samples analyzed for hydrogen sulfide was performed using a Jerome 631-X analyzer. Table 1 indicates the range and accuracy of the analyzer used.

ANALYZER MODEL	GAS	RANGE	INCREMENT	ACCURACY <sup>1</sup>
Jerome 631-X	H₂S	0.003 - 50 ppm	0.001 ppm	Range 0: ±0.003 ppm at 0.050 ppm Range 1: ±0.03 ppm at 0.50 ppm Range 2: ±0.3 ppm at 5.0 ppm Range 3: ±2 ppm at 25 ppm

#### Table 1: Gas Analyzer Range and Accuracy

#### **TEST NOTES OR DEVIATIONS:**

Testing performed without deviation unless noted below.

#### **TEST PARAMETERS:**

## Table 2: Chamber Conditions During Test Period

	PARAMETER	SYMBOL	VALUE	UNITS
Chamb	er Volume	V	30	m³
Testing	g Duration	t	4	h
est itions	Average Temperature (Range)	т	24.2 (23.9-24.3)	°C
Te Condi	Average Humidity (Range)	RH	48.3 (47.5-51.8)	% RH

#### **TEST RESULTS:**

# Table 3: Concentration of challenge chemical decay through test.

Time (min)	H₂S (ppm)	Time (min)	H₂S (ppm)
5	5.2	125	0.44
10	4.6	130	0.40
15	4.0	135	0.36
20	3.7	140	0.32
25	3.4	145	0.28
30	3.0	150	0.27
35	2.8	155	0.23
40	2.4	160	0.21
45	2.2	165	0.18
50	2.1	170	0.17
55	1.9	175	0.15
60	1.7	180	0.13
65	1.6	185	0.12
70	1.4	190	0.11
75	1.3	195	0.10
80	1.2	200	0.09
85	0.94	205	0.08
90	0.85	210	0.07
95	0.77	215	0.06
100	0.72	220	0.06
105	0.65	225	0.05
110	0.59	230	0.05
115	0.54	235	0.04
120	0.49	240	0.04

TEST REPORT FOR TIMILON TECHNOLOGY ACQUISITIONS, LLC

Report No.: 104321905GRR-002 P.O.: 2781

Date: 09-June-2020



Figure 1: Concentration change throughout test for challenge chemicals



Figure 2: Removal rate of challenge chemicals.

## TEST REPORT FOR TIMILON TECHNOLOGY ACQUISITIONS, LLC

Date: 09-June-2020

Report No.: 104321905GRR-002 P.O.: 2781

The clean air delivery rate (CADR) is calculated according to equation 1:

$$ln\left(\frac{C_t}{C_0}\right) = -\left(k_n + \frac{CADR}{V}\right)t$$
 Eq. 1

where:

 $C_t$ : chemical concentration at time t ( $\mu$ g/m<sup>3</sup>)

 $C_0$ : chemical concentration at time  $t_0$  (µg/m<sup>3</sup>)

- *V*: volume of the test chamber (m<sup>3</sup>)
- t: time (h)

CADR: Clean Air Delivery Rate (m<sup>3</sup>/h)

 $k_n$ : first order decay constant with PAC turned off

The single pass efficiency (SPE) is calculated according to equation 2:

$$SPE = \frac{CADR}{Q}$$
 Eq. 2

where:

*Q*: purifier flow rate (425  $m^3/h$ ).

#### Table 2: Purifier efficiency – calculation of clean air delivery rate and single pass efficiency.

VOC	CAS No.	CADR (m <sup>3</sup> /h)	SPE (%)
Hydrogen Sulfide	7783-06-4	36	9

\*CADR and SPE cannot be determined due to correlation coefficient being below 0.9

TEST REPORT FOR TIMILON TECHNOLOGY ACQUISITIONS, LLC Date: 09-June-2020

Report No.: 104321905GRR-002 P.O.: 2781

# **PHOTOGRAPHS:**



Report No.: 104321905GRR-002 P.O.: 2781

# **SECTION 4**

FACILITIES AND EQUIPMENT: HYDROGEN SULFIDE ANALYZER

INSTRUMENTATION USED:

Jerome 631-X-H2S Analyzer Sensor 12-5-22-R2A